

Customer:	Internal	kW Rating:	2000kW	Date:	9/28/2017
Address:		Model:	CAT XQ2000	Technician:	
Contact:		Serial Number:	7RN01418	Job #:	

Time	Load %	kW	A	Amps B	C	A-B	Volts A-C	B-C	Hz	Oil Pressure	Water Temp.	Ambient Temp.
8:50 AM	0	0	0	0	0	480	480	480	60	70	180	70
9:00 AM	100	1988	2358	2421	2410	477	482	476	60	65	185	70
9:05 AM	100	2002	2365	2438	2426	481	481	480	60	64	187	70
9:10 AM	100	2003	2362	2437	2425	481	481	480	60	63	189	70
9:15 AM	100	2002	2362	2435	2429	481	482	480	60	62	190	70
9:20 AM	100	2003	2362	2435	2427	481	481	480	60	62	190	70
9:25 AM	100	2002	2362	2434	2426	481	481	480	60	62	192	70
9:30 AM	100	2004	2362	2435	2426	481	481	480	60	62	192	72
9:35 AM	100	2003	2362	2435	2425	481	481	480	60	62	192	72
9:40 AM	100	2004	2362	2436	2426	481	481	480	60	62	194	72
9:45 AM	100	2003	2361	2435	2424	481	482	480	60	62	194	72
9:50 AM	100	2004	2360	2433	2423	481	482	480	60	63	194	72
9:55 AM	100	2004	2360	2434	2423	481	482	480	60	63	194	73

COMMENTS: