

<b>Customer:</b>	Internal	<b>kW Rating:</b>	400kW	<b>Date:</b>	5/8/2020
<b>Address:</b>	5123 Hiltonview Rd. Houston, TX 77086	<b>Model:</b>	XQ400	<b>Technician:</b>	
<b>Contact:</b>		<b>Serial Number:</b>	X4R00329	<b>Job #:</b>	2206

Time	Load %	kW	Amps			Volts			Hz	Oil Pressure	Water Temp.	Ambient Temp.
			A	B	C	A-B	A-C	B-C				
12:30PM	0	0	-	-	-	481	481	482	60.1	78	117	
12:30PM	50	209	250	251	251	481	481	482	60.1	77	135	
12:45PM	75	314	373	374	374	483	482	482	60.1	66	189	
1:00PM	100	400	476	477	478	483	484	484	60.1	64	184	
1:15PM	100	400	476	477	477	484	484	483	60.1	63	190	
1:30PM	100	400	474	475	476	484	483	482	60.1	63	191	

**COMMENTS: 15 Minutes @ 50% Load; 15 Minutes @ 75% Load; 30 Minutes @ 100% Load**  
 If load requirements are not achievable due to load bank steps, load unit as close to the load requirement as possible. Record in notes section below.